

4G 阀控使用说明

The screenshot displays the '4G 阀控' (4G Valve Control) application interface. At the top, there's a teal header bar with a back arrow, the text '浅埋...', and icons for settings, zoom, and refresh. Below the header, the device ID '3000030003012001' is shown next to a Wi-Fi icon. The main content area lists various device parameters and controls:

- 设备号 (Device ID): 861143075421053
- 卡号 (Card Number): 898604F81623D0199552
- BL版本号 (BL Version Number): 10015
- 当前版本号 (Current Version Number): 10061
- 最新版本号 (Latest Version Number): 0
- 更新固件 (Update Firmware): Includes buttons for '检查更新' (Check for updates) and '立即更新' (Update now).
- 电池电压 (Battery Voltage): 4.1v
- 充电电压 (Charging Voltage): 5.61v
- 操作日志 (Operation Log): Includes a link to '查看日志' (View log).
- 阀门通道1 (Valve Channel 1): Includes '打开' (Open) and '关闭' (Close) buttons.
- 阀门通道2 (Valve Channel 2): Includes '打开' (Open) and '关闭' (Close) buttons.
- 定时策略01 (Timing Strategy 01):
 - 使能状态 (Enable Status): Includes '禁用' (Disable) and '启用' (Enable) buttons.
 - 控制通道 (Control Channel): Includes '通道1' (Channel 1) and '通道2' (Channel 2) buttons.
 - 打开时间 (Open Time): 00:00
 - 关闭时间 (Close Time): 00:00
 - 打开时长 (Open Duration): 0 分钟

At the bottom, there's a microphone icon, a '按住说话' (Press and hold to speak) button, and a '设置' (Settings) button.

- 1、阀门通道 1 和阀门通道 2 是阀门开关
- 2、定时策略支持 8 个，条件策略支持 4 个。每个定时策略都相当于一个每日执行的闹钟, 使能状态在启用的状态才能启用。如果输入打开时间和关闭时间, 会自动算出 打开时长。如果输入打开时间和打开时长, 会自动算出关闭时间